

Positioning Devices Certified for Canada

COMPANY

HILTI INC

7250 Dallas Pky , Legacy Tower Suite 1000
Plano, TX 75024 United States

E201485

Fixing Devices Investigated to CAN/CSA-C22.2 No. 62275

Cat. No.	Type	Mechanical	Hole Dia.		Panel Thick.	Operating Temp.		Resistant to	Air Handling	IEC 62275
		Str. N	mm		mm	°C		UV Light	Spaces	Type
			Min	Max		Min	Max			
Fixing Device										
X-ECT	21	111	-	-	-	0	65	-	AH-2	-

Positioning Devices Investigated to CSA-C22.2 No. 18.5

Catalog No.	Maximum Use Temp, °C
Cable Clamps	
X-ECH/FR-L+	65
X-ECH/FR-M+	65
X-ECH/FR-S+	65
X-EKSC 16	65
X-EKSC 20	65
X-EKSC 25	65

X-EKSC 32	65
X-EKSC 40	65

+ - May be followed by U37 indicating the clamp is provided with the optional steel pin fasteners.

Last Updated on 2023-05-17

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."